

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: A - 001-Monthly

Facility: City of Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip:

72064

Contact: Chad Swaim

Phone: 870-456-0414

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Permit Limits
Sep. 13th, 20th, 2021	TSS	15.5 mg/l Mo Avg	15.0 mg/l Mo Avg
Sep. 13th, 20th, 2021	CBOD	37.0 mg/l Mo Avg	23.0 mg/l Mo Avg
Sep. 13th, 20th, 2021	Fc	>2400 MPN/100mls	2000 MPN/100mls

We feel this problem was due to:

Our finishing/polishing pond had large amounts of sludge

We plan on correcting the problem in this manner:

We have rented a pump to pump the sludge into our oxidation pond, waste more often.

Time estimated that it will take to correct the problem/s:

2 weeks

Sincerely,



Authorized Signature

10-26-21

Date