

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022411

Discharge Number: 001-A-Monthly

Facility: Hazen

Address: 1789 Utility Street

City: Hazen

State: AR

Zip: 72064

Contact: Chad Swaim

Phone:

8708308198

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
September-23	TSS		18.25mg/L MO Avg	15.0mg/L Mo Avg
September-23	TSS		33.00mg/L 7 Day Avg	22.5mg/L 7 Day Avg
September-23	Fecal		>2420MPN/100mL 7D Geo	2000MPN/100mL 7D Geo
September-23	Fecal		1356MPN/100 30D Geo	1000MPN/100 30D Geo

We feel this problem was due to:

TSS - We had an aeration go out

Fecal - We installed new U.V. lights ~~we installed~~

We plan on correcting the problem in this manner:

We plan to fix the aeration

We also have installed the new U.V. system

Time estimated that it will take to correct the problem/s:

1 month

Sincerely,

10-25-23

Authorized Signature



Date