

PINE BLUFF WASTEWATER UTILITY

1520 S. OHIO ST. • PINE BLUFF, ARKANSAS 71601-6055 • PHONE: (870) 535-6603 • FAX (870) 535-6243

June 15, 2020

Christina Brown, Enforcement Analyst
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317


Re: Pine Bluff Wastewater Utility, NPDES Permit Number AR0033316 - AFIN 35-00149

Dear Ms. Brown,

On June 10th 2020, Pine Bluff Wastewater was notified of a possible sewage leak. We dispatched personnel to discover there was a Sanitary Sewer Overflow (SSO) located at 1701 Jefferson Parkway (Twin Rivers Paper Mill) property. We believe the condition may be due to sewer gases causing the top of the ductile pipe to etch away over a period of many years. The overflow condition appears to be contained on the property and no evidence of adverse health/environmental impact. Pine Bluff Wastewater Utility's staff has met with the property owner's staff to discuss plans to repair the pipe. Pine Bluff Wastewater Utility will begin necessary remediation once the repair work is completed.

Should you have any questions or concerns, please feel free to contact me at (870) 535-6603.

Sincerely,


Vincent Miles
E.C. Supervisor

Cc: Ken Johnson, General Manager



PINE BLUFF WASTEWATER UTILITY

1520 S. Ohio Street • Pine Bluff, Arkansas 71601-6055

Serving Our Community, While Protecting The Environment

CERTIFIED MAIL



7015 1520 0002 0963 8

US POSTAGE
\$006.90

First-Class

ZIP 71601

06/16/2020

036B 0011811446

Christina Brown, Enforcement Analyst
ADEQ

5301 Northshore Drive
North Little Rock, AR 72118-5317

72118-531799

