

(ATTACHMENT)

**BOYD POINT TREATMENT FACILITY
EFFLUENT DISCHARGE MONITORING REPORT
JULY 2019**

COMMENTS:

- Discarded the effluent CBOD on July 12, 2019, due to the seed D.O. depletion not meeting the requirements according to standard method.

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT