

(ATTACHMENT)

**BOYD POINT TREATMENT FACILITY  
EFFLUENT DISCHARGE MONITORING REPORT  
MARCH 2020**

**COMMENTS:**

- Discarded the Effluent BOD on March 25 & 26, 2020, due to the final D.O. depletion not meeting the requirements according to standard method.

---

SIGNATURE OF PRINCIPAL EXECUTIVE  
OFFICER OR AUTHORIZED AGENT