

# Sanitary Sewer Overflow Monthly Report

**Facility Name:** Pine Bluff Wastewater Utility **Permit Number:** AR0033316 **Reporting Period(Month/Year)** February 2021

 No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions		
Cause(s) of SSO	SSO Impact	Action(s) Taken
CO-Construction	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order
E-Equipment Failure	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup
HC-Hydro Clean	EFK-Evidence of Fish Kill	HC-Hydro Cleaned
R-Rainfall		HR-Hand Rodded
RO-Roots		EN-Referred to Engineering
		PN-Public Notification
		GR-Ground Surface
		PA-Paved Area
		CB-Contained in Building
		CR-Creek/Stream/River (please specify)
		DI-Ditch
		DR-Drop Inlet

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
1415 Front Street	N-13-021	2/26/2021	2/26/2021	1,500	R	NEAH	HC,EC	GR

Digitally signed by Vincent Miles  
 email=vincent@pinessewer.com, c. US  
 Date: 2021.02.16 08:39:05 -0500

**Vincent Miles**

Signature of Cognizant or Ranking Official

3/17/2021

Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."