

ADEQ

ARKANSAS
Department of Environmental Quality

August 27, 2013

Harold Baker
El Dorado Water Utilities
P.O. Box 1587
El Dorado, AR 71731

RE: NPDES Permit Number AR0033723, AFIN 70-00341
NPDES Permit Effluent Violations

Dear Mr. Baker,


A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending March 2013 and April 2013:

Monitoring Period	Discharge Number	Parameter	Violation	Limit
3/31/13	001-A	NH3-N (Mon. Avg., mg/l)	17.2	6.8
3/31/13	001-A	NH3-N (7 Day Avg., mg/l)	22.7	17
4/30/13	001-A	NH3-N (Mon. Avg., lbs/day)	509.6	239.4
4/30/13	001-A	NH3-N (Mon. Avg., mg/l)	24.6	4.1
4/30/13	001-A	NH3-N (7 Day Avg. mg/l)	29.7	10.1

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit requires you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0633 or e-mail at schluterman@adeq.state.ar.us.

Sincerely,



Amy Schluterman
Enforcement Analyst
Water Division, Enforcement Branch