

From: [John Peppers](#)
To: [Pemberton, Layne](#); "Lorraine Murtha"; [Amanda Gallagher](#)
Subject: Re: AR0033723 EWU North notification
Date: Monday, April 30, 2018 1:58:11 PM

This was just a heads up to expect to see this in the April AR0033936 DMR. It has all been remediated and there will be no need for a five day follow up. Thanks, John

On 4/30/2018 10:57 AM, Pemberton, Layne wrote:

John,

Your notification has been received.

Will there be a five day follow-up report or has the overflow been completely remediated?

Thank you,

Layne Pemberton
Enforcement Analyst
ADEQ Office of Water Quality
Enforcement Branch
Phone: 501-682-0664
Fax: 501-682-0880
pemberton@adeq.state.ar.us



From: John Peppers [<mailto:johnp@eldoradowater.com>]
Sent: Monday, April 30, 2018 10:52 AM
To: Pemberton, Layne; 'Lorraine Murtha'; Amanda Gallagher
Subject: notification

Layne, I just wanted to give you a heads up that we had a check valve fail in the lift station that feeds the daf units at our north treatment plant. This caused a flooding condition in the lift station that required us to pump the water out of the lift station and onto the ground within the confines of company property. The volume was approximately 1500 gallons. The discharge was monitored by company personnel and none of it reached waters of the state. It should be noted that the water was not from the influent but was after the final pond and was just prior to solids removal and posed no health or environment risk. The official notification will be on the April 2018 DMR.

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com

<!--[if !supportLineBreakNewLine]-->

<!--[endif]-->

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764

