

From: [John Peppers](#)
To: [Pemberton, Layne](#); ["Lorraine Murtha"](#); [Amanda Gallagher](#)
Subject: notification
Date: Monday, April 30, 2018 10:51:27 AM

Layne, I just wanted to give you a heads up that we had a check valve fail in the lift station that feeds the daf units at our north treatment plant. This caused a flooding condition in the lift station that required us to pump the water out of the lift station and onto the ground within the confines of company property. The volume was approximately 1500 gallons. The discharge was monitored by company personnel and none of it reached waters of the state. It should be noted that the water was not from the influent but was after the final pond and was just prior to solids removal and posed no health or environment risk. The official notification will be on the April 2018 DMR.

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com