



June 25, 2019

John Peppers, Treatment Super.  
El Dorado Water Utilities - South  
P.O. Box 1587  
El Dorado, AR 71731

Email: [johnp@eldoradowater.com](mailto:johnp@eldoradowater.com)

RE: NPDES Permit Number AR0033723, AFIN 70-00341  
NPDES Permit Effluent Violation

Dear Mr. Peppers,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting periods.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
04/30/2019	010S-A	Solids, total suspended, DAILY MX, lb/d	2627.1	3377.5	29%	E90	00530-1-0
04/30/2019	010S-A	Solids, total suspended, DAILY MX, mg/L	45	88	96%	E90	00530-1-0
03/31/2019	010S-A	Solids, total suspended, DAILY MX, mg/L	45	54	20%	E90	00530-1-0

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or via e-mail at [pemberton@adeq.state.ar.us](mailto:pemberton@adeq.state.ar.us).

Sincerely,

Layne Pemberton  
Enforcement Analyst  
Office of Water Quality  
NPDES Enforcement Section