

June 7, 2018

John Peppers, Treatment Super. El Dorado Water Utilities P.O. Box 1587 El Dorado, AR 71731 Email: johnp@eldoradowater.com

## RE: NPDES Permit Number AR0033723, AFIN 70-00341 NPDES Permit Effluent Violation

Dear Mr. Peppers,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting periods.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value
04/30/2018	010S-A	pH, MINIMUM, SU	>=6	5.6
04/30/2018	010S-A	Solids, total suspended, DAILY MX, lb/d	2627.1	2816.1
04/30/2018	010S-A	Solids, total suspended, DAILY MX, mg/L	45	74

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or via e-mail at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pouteto

Layne Pemberton Enforcement Analyst Office of Water Quality NPDES Enforcement Section