



October 14, 2019

John Peppers, Treatment Super.
El Dorado Water Utilities - South
P.O. Box 1587
El Dorado, AR 71731

Email: johnp@eldoradowater.com

RE: NPDES Permit Number AR0033723, AFIN 70-00341
NPDES Permit Effluent Violation

Dear Mr. Peppers,

The Department has conducted a file review of the above referenced permit and determined your facility reported the following violations of the effluent limitations in Part I, Section A of your Permit for the following reporting period.

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code	Parameter Code
05/31/2019	010S-A	Solids, total suspended, DAILY MX, mg/L	45	60	33%	E90	00530-1-0

Failure to remain in compliance with the effluent limitations set forth in your permit violates Part I, Section A of your permit, and may result in formal enforcement action that will include the assessment of a civil penalty.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0664 or via e-mail at pemberton@adeq.state.ar.us.

Sincerely,

Layne Pemberton
Enforcement Analyst
Office of Water Quality
NPDES Enforcement Section