

**From:** [John Peppers](#)  
**To:** [Pemberton, Layne](#); [Amanda Gallagher](#)  
**Subject:** 5/14/19 TSS permit exceedance  
**Date:** Wednesday, May 22, 2019 2:19:06 PM

---

Layne, the south plant had a TSS permit exceedance on 5/14/19. The TSS concentration of 55 mg/l exceeds the permit limit of 45 mg/l. This was due to a malfunctioning DAF unit.

Thank you,

--

***John M. Peppers***  
***Treatment Superintendent***  
***El Dorado Water Utilities***  
***870-814-1764***



This email has been checked for viruses by AVG antivirus software.

[www.avg.com](http://www.avg.com)