

**From:** [John Peppers](#)  
**To:** [Pemberton, Layne](#); [Shelby Spence](#); [Amanda Gallagher](#)  
**Subject:** 4/19/18 exceedance  
**Date:** Thursday, April 26, 2018 11:47:02 AM

---

Layne, the south plant TSS for 4/19/2018 was 74 mg/L which was above our Daily Max Permit (45 mg/L), which at the recorded flow of 4.563 MGD also busted the Daily Max Permit Limit for the Mass limit at 2816.10 lbs/day. We have investigated what may have caused this exceedance and can find no apparent causes outside of the high number of water fleas that are in our effluent at this time of year and wind direction.

Thank you,

--

***John M. Peppers***  
***Treatment Superintendent***  
***El Dorado Water Utilities***  
***870-814-1764***



This email has been checked for viruses by AVG antivirus software.

[www.avg.com](http://www.avg.com)