

From: [John Peppers](#)
To: [Pemberton, Layne](#); [Shelby Spence](#); [Amanda Gallagher](#); "Lorraine Murtha"
Subject: AR0033723 permit exceedences (south plant)
Date: Thursday, May 17, 2018 3:39:32 PM

Layne, this is to inform you that on 5/7/18 and 5/8/18 the pH minimum levels were exceeded. The excursions were 4.8 and 5.4 respectively. These occurred prior to taking the #4 DAF unit out of service which caused these excursions to happen. Since taking the unit out of service, the pH levels have remained within permit limits.

The lab computer is still down and I just received the handwritten results to get this information to you.

Thank you,

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com