

**From:** [John Peppers](#)  
**To:** [Pemberton, Layne](#); ["Robert Edmonds"](#); [Amanda Gallagher](#)  
**Subject:** pH minimum limit excursion  
**Date:** Tuesday, June 12, 2018 4:47:53 PM

---

Layne, on 6/11/18 the south plant (AR0033723) had a pH minimum limit excursion. The reported value was 5.86 and the minimum limit is 6.0. After investigation, we found that the pH meter at the south plant was faulty and it is now being repaired by scientific partners here in El Dorado. If it is found that the meter is unable to be repaired, it will be replaced.

Thank you,

--

***John M. Peppers***  
***Treatment Superintendent***  
***El Dorado Water Utilities***  
***870-814-1764***



This email has been checked for viruses by AVG antivirus software.

[www.avg.com](http://www.avg.com)