

From: [John Peppers](#)
To: [Pemberton, Layne](#); [Amanda Gallagher](#)
Subject: TSS exceedence
Date: Tuesday, April 30, 2019 3:09:29 PM

Layne, on 4/16/19, the south treatment plant (AR0033723) exceeded the daily maximum TSS limit of 45 mg/l with a daily max of 50 mg/l. This was caused by a clogged air valve at the head of the #4 DAF unit. The valve was cycled several times when the issue was discovered which cleared the clog and the unit once again started producing white water.

If you have any questions, please do not hesitate to contact me.

Sincerely,

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.
www.avg.com