

From: [John Peppers](#)
To: [Pemberton, Layne](#); [Amanda Gallagher](#)
Subject: 5/1/19 TSS exceedance
Date: Thursday, May 09, 2019 11:17:58 AM

Layne, the south treatment plant (AR0033723) exceeded it's permit limit of 45 mg/l of TSS with a result of 60 mg/l on 5/1/19. This was due to operator error and they have been retrained in proper operation of the DAF units.

Thank you,

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com