

From: [John Peppers](#)
To: [Pemberton, Layne](#); [Amanda Gallagher](#)
Subject: 4/25/19 TSS permit exceedence
Date: Tuesday, May 07, 2019 10:36:28 AM

Layne, the south treatment plant (AR0033723) exceeded the permit limit of 45 mg/l of TSS with a result of 48 mg/l on 4/25/19. This was a continuation of the previous days exceedence (see my previous email from yesterday) due to a malfunctioning polymer pump.

Thank you,

--

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com