

From: [John Peppers](#)
To: [Pemberton, Layne](#); "Lorraine Murtha"
Subject: five day follow ups
Date: Wednesday, October 11, 2017 11:23:54 AM

Lane, I wanted to give you a couple of five day follow ups.

The first is confirmation number 0eb23585-91ef-44ec-b606-f8eeb0004d4f. This is the 1102 Glenwood address. The work is still on-going as a tree had to be cut by a contractor and a portable storage building moved for repairs to begin. I will send you another update on this address once repairs are completed. Reportedly, the discharge is a very small one.

The second is confirmation number 38f35fe9-0b89-4404-99a6-1a05f8533038. This is located behind 908 Haney. The line was overflowing slightly into a drainage ditch and going into the storm drain system. The line was unstopped and returned to normal operation.

If you have any questions, please do not hesitate to call me.

Thank you,

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764

