

ADEQ

ARKANSAS
Department of Environmental Quality

January 19, 2012

Larry Waldrop
El Dorado Water Utilities-South Plant
PO Box 1587
El Dorado, AR 71730

RE: NPDES Permit Number AR0033723, AFIN 70-00341

Dear Mr. Waldrop:

A recent review of the NPDES file for **El Dorado Water Utilities-South Plant** has revealed the following violation for the monitoring periods ending **9/30/2011 and 10/31/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	DATE
TX1-Q	Whole effluent toxicity (Daily Avg. Min.)	56	100	9/30/2011
TX1-Q	Whole effluent toxicity (7 Day Min.)	56	100	9/30/2011
001-A	Ammonia Nitrogen (Mo Avg.)	3.2	2.4	10/31/2011
001-A	Ammonia Nitrogen (7 Day Avg.)	6.8	6.1	10/31/2011

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0033723** and AFIN **70-00341** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0667 or e-mail bolenbaughm@adeq.state.ar.us.

Sincerely,



Michelle Bolenbaugh
Enforcement Analyst
Water Division Enforcement Branch