

From: [John Peppers](#)
To: [Pemberton, Layne](#); ["Lorraine Murtha"](#); ["Robert Edmonds"](#); [Amanda Gallagher](#)
Subject: 4/12/18 TSS permit exceedence for AR0033723
Date: Friday, April 20, 2018 3:32:03 PM

Layne, this email is to inform you that on 4/12/18 we had a TSS permit exceedence of 51mg/l. This was likely due to a high number of biologicals (water fleas) in the sample along with wind direction on the final polishing pond. We were within permit limits on the day before and were back within permit limits the following day.

Thank you,

John M. Peppers
Treatment Superintendent
El Dorado Water Utilities
870-814-1764



This email has been checked for viruses by AVG antivirus software.

www.avg.com