

NPDES Permit No. AR0033723
City of El Dorado – South Plant
010S Outfall
Non-Compliance Report
April 2022

All parameters sampled at Outfall 010S were within permit limits except for the following:

Outfall	Parameter	Date	Permit Limit	Sample Result
010S	Total Suspended Solids (TSS)	04/28/2022	Daily Maximum 45 mg/L	51 mg/L

The collection tube on the automatic sampler contained excessive algae growth. The tube was replaced on April 28th. TSS concentrations were within permit limits on April 29th.