

NPDES Permit No. AR0033723
City of El Dorado – South Plant
010S Outfall
Non-Compliance Report
January 2022

All parameters sampled at Outfall 010S were within permit limits except for the following:

Outfall	Parameter	Date	Permit Limit	Sample Result
010S	Total Suspended Solids (TSS)	01/24/2022	Daily Maximum 45 mg/L	60 mg/L
010S	Total Suspended Solids (TSS)	01/25/2022	Daily Maximum 45 mg/L	54 mg/L

The TSS concentration levels were in compliance on January 24th and 25th. The operator did not properly adjust the chemical feed to the DAF unit in order to maintain TSS concentrations below the permitted levels. Additional training was provided to prevent future reoccurrences. The TSS concentrations remained in compliance the remainder of the month. City of El Dorado will continue to carefully monitor the treatment system and maintain appropriate TSS concentrations.