

**NPDES Permit No. AR0033723**  
**City of El Dorado – South Plant**  
**010S Outfall**  
**Non-Compliance Report**  
**October 2023**

All parameters sampled at Outfall 010S were within permit limits except for the following:

<b>Outfall</b>	<b>Parameter</b>	<b>Date</b>	<b>Permit Limit</b>	<b>Sample Result</b>
010S	Total Suspended Solids (TSS)	10/04/2023	Daily Maximum 45 mg/L	72 mg/L

The high TSS concentration on October 4<sup>th</sup> was due to a clogged chemical feed pump that distributes polymer to the DAF unit. The TSS concentrations were in compliance in the days before and after October 4<sup>th</sup>. The City of El Dorado will continue to carefully monitor the treatment system and maintain appropriate TSS concentrations.