

NPDES Permit No. AR0033723
City of El Dorado – South Plant
010S Outfall
Non-Compliance Report
April 2021

All parameters sampled at Outfall 010S were within permit limits except for the following:

Outfall	Parameter	Date	Permit Limit	Sample Result
010S	Total Suspended Solids (TSS)	04/09/2021	Daily Maximum 45 mg/L	48 mg/L

There were no obvious indicators for the slightly elevated TSS levels at Outfall 010S on April 9th. The TSS concentration levels were back within compliance the following day and remained in compliance the remainder of the month. City of El Dorado will continue to carefully monitor the treatment system and maintain appropriate TSS concentrations.