

**NPDES Permit No. AR0033723**  
**City of El Dorado – South Plant**  
**010S Outfall**  
**Non-Compliance Report**  
**November 2021**

All parameters sampled at Outfall 010S were within permit limits except for the following:

<b>Outfall</b>	<b>Parameter</b>	<b>Date</b>	<b>Permit Limit</b>	<b>Sample Result</b>
010S	Total Suspended Solids (TSS)	11/01/2021	Daily Maximum 45 mg/L	58 mg/L

The TSS concentration levels were in compliance on October 30<sup>th</sup> and November 2<sup>nd</sup>. The operator did not properly adjust the chemical feed to the DAF unit in order to maintain TSS concentrations below the permitted levels. Additional training was provided to prevent future reoccurrences. The TSS concentrations remained in compliance the remainder of the month. City of El Dorado will continue to carefully monitor the treatment system and maintain appropriate TSS concentrations.