

PERMITTEE Paragould Light, Water and Cable - Wastewater Treatment Plant
PERMIT NO. AR0033766

DATE OF VIOLATION Month of January 2015

PARAMETER VIOLATED Monthly Average CBOD₅

REPORTED DISCHARGE Monthly Average CBOD₅: 10.4 mg/L

PERMIT CONDITION Monthly Average CBOD₅: 10 mg/L

A description of the noncomplying discharge including its impact upon the receiving waters:
Average of CBOD₅ values were above permitted condition; there were no observable impacts to the receiving stream.

Cause of the non-compliance:
The violation was caused by low dissolved oxygen levels in the Oxidation Ditches.

Anticipated time the condition of noncompliance is expected to continue or, if it has been corrected, the duration of the period of noncompliance:
At the present time, the plant is in compliance.

Steps taken to reduce or eliminate the noncomplying discharge:
Dissolved Oxygen levels will be evaluated at least twice a day to ensure the levels remain at the appropriate level for proper treatment of CBOD₅.

Steps taken to prevent recurrence of the condition of noncompliance:
Operators will closely monitor the dissolved oxygen levels in the Oxidation Ditches to ensure levels are appropriate for removal of CBOD₅.

2-13-2015
Date


Signature