

870-239-7700 Fax: 870-239-7798 www.paragould.com

April 11, 2016

Arkansas Department of Environmental Quality NPDES Enforcement Section 5301 Northshore Drive North Little Rock, AR 72118-5317

Re:

NPDES Permit # AR0033766 – Paragould Light Water & Cable (PLWC)

March 2016 Permit Violations

To Whom It May Concern:

I regret to inform you that the wastewater treatment plant was in non-compliance during the month of March 2016. The non-compliance was for the TRC instantaneous maximum limit, which was at the MDL of 0.02 ppm. Unfortunately PLWC was unable to determine the cause of the violations, but based on TRC analytical results taken throughout the system believe interference resulted in false positive TRC results in the effluent. See the attached non-compliance report for more details.

PLWC is currently in the process of installing UV Disinfection to eliminate the chlorine and sulfur dioxide feed systems. Current plans are to have the new system operational by the end of May 2016.

If you have any questions or comments, please call Lisa Ellington, Manager of Environmental Services, at (870) 239-7795. Thank you.

Sincerely, Shillips

Darrell Phillips

General Manager/CEO