

PERMITTEE Paragould Light, Water and Cable - Wastewater Treatment Plant
PERMIT NO. AR0033766

DATE OF VIOLATION September 8 - 12, 2015

PARAMETER VIOLATED CBOD₅ Weekly Average
CBOD₅ Monthly Average

REPORTED DISCHARGE CBOD₅ Weekly Average: 17.3 ppm
CBOD₅ Monthly Average: 13.1 ppm

PERMIT CONDITION CBOD₅ Weekly Average: 15.0 ppm
CBOD₅ Monthly Average: 10.1 ppm

A description of the noncomplying discharge including its impact upon the receiving waters:
CBOD₅ Weekly and Monthly Averages were above permit limits; there were no observable impacts to the receiving stream.

Cause of the non-compliance:
The violations were due to contaminated hosing on the automatic sampler.

Anticipated time the condition of noncompliance is expected to continue or, if it has been corrected, the duration of the period of noncompliance:
At the present time, the plant is in compliance.

Steps taken to reduce or eliminate the noncomplying discharge:
Operators have been instructed to replace the automatic sampler hose every week.

Steps taken to prevent recurrence of the condition of noncompliance:
In addition to replacing the sampler hose each week, a log book has been created to ensure hoses are changed weekly. The Manager will check each Friday to verify changing of the hoses.

10-12-2015
Date

Darrell Phillips
Signature