



"One Team, One Goal...Customer Service"

870-239-7700
Fax: 870-239-7798
www.paragould.com

October 12, 2015

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: NPDES Permit # AR0033766
September 2015 Permit Violations

To Whom It May Concern:

I regret to inform you that the wastewater treatment plant was in non-compliance for the month of September 2015. The non-compliances were for the CBOD₅ weekly and monthly averages. The violations were caused by contaminated hose on the automatic sampler. See the attached noncompliance report for more details.

If you have any questions or comments, please call Lisa Ellington, Manager of Environmental Services, at (870) 239-7795. Thank you for your assistance.

Sincerely,

A handwritten signature in black ink that reads "Darrell Phillips". The signature is written in a cursive, flowing style.

Darrell Phillips
General Manager/CEO