

Anderson, Alan

From: Anderson, Alan
Sent: Monday, July 27, 2015 8:32 AM
To: 'Lisa Ellington'
Subject: RE: Permit renewal

Follow Up Flag: Follow up
Flag Status: Flagged

Thanks for the update Lisa

From: Lisa Ellington [<mailto:lellington@paragould.com>]
Sent: Friday, July 24, 2015 11:03 AM
To: Anderson, Alan
Cc: Kevin White
Subject: RE: Permit renewal

Good morning Alan,

According to our consulting engineer, Kevin White who has been included on this email, the UV equipment has been ordered with an expected arrival date of November 1, 2015. Plans and specifications should be ready to bid the construction project sometime around the first of August, and awarding of the bid should be completed toward the end of August/first part of September. The contractor should be ready to start construction mid-September, with completion of the project by the end of December.

If you need additional information please contact me.

Thanks and have a great weekend!

*Lisa Ellington
Environmental Services Manager
Paragould Light, Water & Cable
P.O. Box 9
Paragould, AR 72450
Phone (870) 239-7795
Fax (870) 239-7791
lellington@paragould.com*



From: Anderson, Alan [<mailto:ANDERSON@adeq.state.ar.us>]
Sent: Friday, July 24, 2015 10:10 AM
To: Lisa Ellington
Subject: RE: Permit renewal

Good Morning Lisa:

Could you give me a brief update on the progress of the UV system. Also, is there a date established for when the installation will be started and completed.

Thank You

Alan

From: Lisa Ellington [<mailto:lellington@paragould.com>]
Sent: Friday, May 29, 2015 2:40 PM
To: Anderson, Alan
Subject: RE: Permit renewal

Good afternoon Alan,

Based on reports, most noncompliances with TRC was due to the equipment not working properly. Currently WWTP operators check chlorine and sulfur dioxide equipment daily to ensure proper operation. Also, the company who installed the equipment has been here several times to work on the system.

Plans are for PLWC to install a UV system during the 4th quarter this year. This will eliminate the use of chlorine and sulfur dioxide. Our consulting engineers are in the design phase of the project, and once complete it will be sent to ADEQ for approval. After the system is installed and operational, PLWC will request a permit revision from ADEQ.

Let me know if you need additional information.

Have a great weekend!

Lisa

*Lisa Ellington
Environmental Services Manager
Paragould Light, Water & Cable
P.O. Box 9
Paragould, AR 72450
Phone (870) 239-7795
Fax (870) 239-7791
lellington@paragould.com*

From: Anderson, Alan [<mailto:ANDERSON@adeq.state.ar.us>]
Sent: Friday, May 29, 2015 1:54 PM
To: Lisa Ellington
Subject: Permit renewal

Hi Lisa:

I am working with the Permit Engineer to get the Discharge Permit renewed. I actually did the review a year ago, but am doing a short follow up. so if I could get the following info from you that would be great.

A brief summary of the corrective actions to eliminate the TRC violations:

Thanks

Alan Anderson
Enforcement Analyst
ADEQ Water Division
501-682-0635