

## Anderson, Alan

---

**From:** Lisa Ellington <lellington@paragould.com>  
**Sent:** Thursday, March 12, 2015 8:44 AM  
**To:** Anderson, Alan  
**Cc:** Darrell Phillips  
**Subject:** NPDES Permit #AR0033766 - Unanticipated Bypass

Mr. Anderson,

As required by NPDES Permit #AR0033766 for Paragould Light Water and Cable (PLWC), this serves as notification that the PLWC WWTP facility has experienced an unanticipated bypass from the overflow lagoon due to melting of wintry precipitation and rainfall.

The bypass in the lagoon began on March 10, 2015 at approximately 11:00 AM and ended on March 12, 2015 at approximately 4:00 AM. It is estimated a total of 984,000 gallons were discharged. As discussed during our phone conversation this morning, we are diligently working to bring down the water level in the lagoon. However, it is predicted our area will receive additional rainfall today and tomorrow. As such, another unanticipated bypass may occur, and you will be notified as soon as possible if this event takes place.

Samples as of the lagoon discharge were taken for analysis. Those results will be sent to you as soon testing is complete and information compiled.

If you have questions or need additional information, please do not hesitate to contact me. Thank you for your assistance in this matter.

*Lisa Ellington  
Environmental Services Manager  
Paragould Light, Water & Cable  
P.O. Box 9  
Paragould, AR 72450  
Phone (870) 239-7795  
Fax (870) 239-7791  
[lellington@paragould.com](mailto:lellington@paragould.com)*