From:	Harold Mauldin
To:	SSOADEQ
Cc:	Shawn Davis
Subject:	High Flow Event
Date:	Friday, September 25, 2020 3:52:33 PM
Attachments:	image001.png

Confirmation Number: e0afcd6c-30b7-4028-bcf1-1461759eaf9c

On Tuesday, September 22nd 2020, the City of Hot Springs Davidson Wastewater Treatment Plant (Permit Number 0033880) at 320 Davidson Drive experienced a high flow event.
The Influent Flow pipe entering the plant overflowed from a leak in the pipe forcing water to flow into a nearby stream and entering into Lake Catherine. It is estimated an additional 10,000 gallons of water overflowed from the pipe since the confirmation number was issued. (90,000 gallons total).
We placed lime on the area affected and repairs to the pipe will take place on the week of October 5th 2020.
The overflow began at 1130am on Tuesday, September 22nd 2020 and ended on Wednesday, September 23rd 2020 at 3:30pm.
Should you have any questions, please feel free to call.

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
501-262-1125