From:	Harold Mauldin
To:	SSOADEQ
Cc:	Allen-Daniel, Leslie
Subject:	5-DAy Report
Date:	Friday, February 21, 2020 4:53:00 PM

On Tuesday, February 18th 2020 at 3:06pm, the City of Hot Springs Davidson Wastewater Treatment Plant (permit number AR0033880) at 320 Davidson Drive experienced a high flow event. Because of high flows and a full Equalization Pond, we had no choice but to open the blending valve at the Primary Clarifier Effluent. This caused approximately 33 Million Gallons to bypass Secondary Treatment and reach UV Disinfection. The Blending Valve was opened from Tuesday, February 18th 2020 at 3:06pm till Friday, February 21, 2020 at 3:20pm. (Confirmation Number ec028b15-455d-4c44-84a0-bd93a86938c8).

If you have any questions, please call or email.

Thank you,

Harold Mauldin

Facilities Operations Manager

City of Hot Springs

501-262-1125