



# ARKANSAS ENERGY & ENVIRONMENT

August 17, 2020

Monty Ledbetter, Utilities Director  
City of Hot Springs  
P.O. Box 700  
Hot Springs, AR 71902

email: [MLedbetter@cityhs.net](mailto:MLedbetter@cityhs.net)

**RE: Permit Number: AR0033880, AFIN: 26-00145  
Effluent Violations**

Dear Mr. Ledbetter:

A review of the Discharge Monitoring Reports (DMRs) submitted in accordance with the permit for the above mentioned facility for the month April 2020, revealed the following violations of the permitted effluent limitations:

The facility has reported the following **2 effluent violations** of Part I, Section A of Permit No. AR0033880:

DMR End Date	Discharge Number	Parameter Description	DMR Value Qualifier Code	Reported DMR Value	Permit Limit	Vio %	Violation Type	DMR Value Type Code	Parameter-Mon. Location-Season
04/30/2020	001-A	Solids, total suspended (MO AVG, lb/d)	=	2080	1500	39%	Numeric Vio	Q 1	00530-1-0
04/30/2020	001-A	BOD, carbonaceous [5 day, 20 C] (MO AVG, lb/d)	=	1128	1000	13%	Numeric Vio	Q 1	80082-1-0

Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Thank you for your attention to this matter.

Should you have any questions concerning the above referenced effluent violations, please feel free to contact me at 501-682-0630, or you may e-mail me at [allen-daniel@adeq.state.ar.us](mailto:allen-daniel@adeq.state.ar.us).

Sincerely,

Leslie Allen-Daniel  
Enforcement Analyst  
Office of Water Quality

Cc: Gordon Yates, Operator [GYates@cityhs.net](mailto:GYates@cityhs.net)

Cc: Harold Mauldin, Facility Operations Mgr. [HMauldin@cityhs.net](mailto:HMauldin@cityhs.net)