

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: 001A

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
Feb 2018	TSS	7001		Mo avg 1500 lbs./day
	TSS		33.09 mg/l 59.14mg/l	15 mg/l 22mg/l
	C-bod		15.95mg/l 35.57 mg/l	10.0mg/l 15.0mg/l
	C-bod	3668		
	Total P	178		Mo avg 100.1 lbs./day

We fill this problem was due to:

Excessive infiltration from storm events , and the fact that the WWTP is under a construction permit for headworks upgrade and not able to treat as much wastewater through the plant , there going on bypass much earlier and longer than in the past.

We plan on correcting the problem in this manner:

With construction completion

Time estimated that it will take to correct problem:

Planned this coming summer

Sincerely,  
James B Sorrells

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date 3-19-2018