

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: 0033880 Discharge Number: 001-A

Facility: City of Hot Springs Wastewater Treatment Plant

Address: 320 Davidson Drive

City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 501-262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
June 2, 2018	Nh3: 7-Day Avg.		7.74	7.5

We feel this problem was due to:

Water from the Equalization Basin, coupled by a rain event,
caused the elevated Ammonia's.

We plan on correcting the problem in this manner:

We have corrected the issue by emptying the Equalization
Basin and returning to normal operations

Time estimated that it will take to correct problem:

We believe the issue is resolved. There have not been
any other issues.

Sincerely,



Authorized Signature

July 24, 2018

Date

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)



City of Hot Springs
Municipal Utilities
Waste Water Treatment Plant

320 Davidson Drive
Hot Springs, Arkansas 71901
(501) 262-1881
(501) 262-0339 Fax

The elevated ammonia's for the month of June was created from the water at the Equalization Basin being pumped back into the treatment process. The retention time, coupled with a rain event, created the increased ammonia for the month of May. The seven day average, reaching into June 2nd, created the non-compliant for the seven day average. The average ammonia for the entire month of June was 2.24 mg/l.

The construction project is virtually complete and we have not had any issues since and look forward to returning to normal operating procedures.

Thank you,

A handwritten signature in cursive script, appearing to read "Harold Mauldin".

Harold Mauldin

Facilities Operations Manager

City of Hot Springs