

## NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive

City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 4, 2019	TSS- 7 Day Average		23.9	22.5
May 2019	TSS –Monthly Average	2337		1500
May 2019	C-BOD <sub>5</sub> – Monthly Average	1257		1000

We feel this problem was due to:

**This was due to high flow into our treatment facilities from the previous month and continuous rains.**

We plan on correcting the problem in this manner:

**Our facility is functioning well at this time and we are making the necessary adjustments. The seasonal rain was the main issue.**

Time estimated that it will take to correct problem:

**The problem has been resolved and we see no other issues, at this time.**

Sincerely,



Submitted By:

June 6, 2019  
Date

### Submitted Electronically via NetDMR

**Certification Statement:** I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)