

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDS Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive

City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
January 9 th 2021	TSS- 7 Day Average		48.61	22.5
January 2021	TSS –Monthly Average		20.3	15.0
January 2021	TSS –Monthly Average	2993		1500
January 2021	Total Phosphorus	112		100

We feel this problem was due to:

High Flows from three major rain events at the beginning of the month.

We plan on correcting the problem in this manner:

Currently, construction is underway for a new Aqua Storm Cloth Filter System that will address the Total Suspended Solids issues.

Time estimated that it will take to correct problem:

Permit Parameters are being met and the new filtration system will be online very soon.

Sincerely,



Submitted By:

2/15/2021
Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)