

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive

City: Hot Springs State: Ar. Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 27 th 2021	TSS- 7 Day Average		37.89	22.5
March	TSS –Monthly Average		27.24	15.0
March 2021	TSS –Monthly Average	3324		1500
March 2021	C-BOD ₅ –Monthly Average	1303		1000

We feel this problem was due to:

We received well over 4” of rain during the month; causing an increase in flow. The pond filled to capacity and we had to blend on two separate occasions.

We plan on correcting the problem in this manner:

Construction for the Aqua Storm Cloth Filter System continues and will be online soon.

Time estimated that it will take to correct problem:

It is estimated that the new filter system will be online sometime in June.

Sincerely,





Submitted By:

Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)