

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0033880 Discharge Number: 001
Facility: City of Hot Springs Wastewater Plant
Address: 320 Davidson Drive
City: Hot Springs State: AR Zip: 71901
Contact: Gordon Yates Phone: 501-262-1125

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3/22/22	total suspended solids	3598.0	19.0	15.0
3/22/22	total suspended solids		75.3	27.5
3/22/22	Phosphorus	129.5		100.1

We feel this problem was due to:

Major Rain Event three to Four inches in a short period, that caused the influent flow to over take
The gates at the head of the plant, causing some of the bio mass thru the secondary clarifiers

We plan on correcting the problem in this manner:

WE are going to have the Bar Screen Bypass opened that goes to the Equalization Pond.
in the future to prevent the washout of the biomass , in the event of a major rain event.

Time estimated that it will take to correct problem:

3/23/22

Sincerely,

Gordon Yates

4/15/22

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)