

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, Ar. 72118

RE: NPDES Permit: AR0033880 Discharge Number: 001A

Facility: City of Hot Springs Regional Wastewater Treatment Plant

Address: 320 Davidson Drive City: Hot Springs State: Ar Zip: 71901

Contact: Harold Mauldin Phone: 1 (501) 262-1125


Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
May 13, 2023	Total Suspended- 7 Day Avg.		25.7	22.5

We feel this problem was due to: Average flow from May 10-13, 2023 was 21.56mgd. The plant is permitted for 12mgd. The 'Blending Valve' was open May 11-May 15, 2023, which diverts part of the flow post primary clarification straight to filtration and UV Disinfection, bypassing secondary clarification.

We plan on correcting the problem in this manner: Installation of secondary control gates could help with levels in secondary's that cause elevation in TSS. Plant expansion is beginning soon to help alleviate the issues with high flows, during rainy seasons.

Time estimated that it will take to correct problem: We hope to have the gates installed within the next six months. Plant expansion will commence once construction permit is issued.

Sincerely,



Submitted By:

June 16, 2023

Date

Submitted Electronically via NetDMR

Certification Statement: I certify under the penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)