

Leslie Allen-Daniel (adpce.ad)

From: Harold Mauldin <HMauldin@cityhs.net>
Sent: Tuesday, January 16, 2024 10:41 AM
To: Water-Enforcement-Report; Leslie Allen-Daniel (adpce.ad)
Cc: Monty Ledbetter; Gordon Yates
Subject: Blending Valve Still Open

Leslie,

Confirmation Number: 72beb063-e54c-4217-a370-474dad7f7462

On Wednesday, January 10, 2024, the Davidson Wastewater Treatment Plant (Permit Number: AR0033880) began blending flow at the Primary Effluent. Since that time, approximately 25 MGD has gone through the blending valve and into UV Disinfection. Because of continued high flows, the blending valve is still open. I will follow up with another email once we are able to return to normal operations.

Thank you,

Harold Mauldin
Facilities Operations Manager
City of Hot Springs
501-621-5041

