From:	Harold Mauldin
To:	SSOADEQ
Cc:	Allen-Daniel, Leslie
Subject:	5-Day Report
Date:	Saturday, February 15, 2020 1:12:19 PM

On Tuesday, February 11th 2020, the City of Hot Springs Davidson Wastewater Treatment Plant (permit number AR0033880) at 320 Davidson Drive experienced a high flow event. Because of high flows and a full Equalization Pond, we had no choice but to open the Blending Valve located at the Primary Clarifiers. This caused approximately 41 million gallons to bypass secondary treatment and reach UV Disinfection.

The Blending Valve was opened from Tuesday, February 11th 2020 till Saturday, February 15, 2020 at 1120am.

If you have any questions or concerns, please feel free to call.

Thank you,

Harold Mauldin

Facilities Operations Manager

City of Hot Springs

501-262-1125