



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### **Analysis Report for Manhole #1750**

On Tuesday, December 28, 2021 samples were taken for fecal coliform/ E.Coli Analysis at four (4) designated locations. The results of the analysis is as follows:

Site 2: E.coli- 261.3 cfu per 100mls / Fecal Coliform- 180 colonies per 100mls

Site 3: E.coli- 124.6 cfu per 100mls/ Fecal Coliform- 85.71 colonies per 100mls

Site 4: E.coli- 36.4 cfu per 100mls / Fecal Coliform- 25.71 colonies per 100mls

Site 5: E.coli- 23.1 cfu per 100mls / Fecal Coliform- 8.57 colonies per 100mls

Site 2 is above the 126 cfu per 100mls recommended by EPA Standards. We will test again in a few days. ADH signs will remain until two consecutive samples are below 126 cfu per 100mls at all four sample sites.

Amanda Cates  
Lab Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs