



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

Analysis Report for Manhole #1750

On Thursday, December 30, 2021, samples were taken for fecal coliform/ E.coli Analysis at four (4) designated locations. The results of the analysis is as follows:

Site 2: E.coli- 920.8cfu per 100mls / Fecal Coliform- 617 colonies per 100mls

Site 4: E.coli- 2419.6 cfu per 100mls / Fecal Coliform- 521 colonies per 100mls

Site 5: E.coli- 613.1 cfu per 100mls / Fecal Coliform- 523 colonies per 100mls

All three sites are above the 126cfu's per 100 mls. Site 3 was under 126 cfu's for two previous samples so there was no analysis at this site. However, ADH signs will remain until two consecutive samples are below 126 cfu per 100mls at sample sites 2, 4 & 5.

Amanda Cates
Lab Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs