| | |
|---|---|
| **From:** | Harold Mauldin |
| **To:** | SSOADEQ |
| **Cc:** | Allen-Daniel, Leslie; Monty Ledbetter |
| **Subject:** | 5-Day Report |
| **Date:** | Saturday, March 7, 2020 12:55:06 PM |

Regarding Confirmation Number: 1d3216f5-5450-4a6d-93dc-97b5d8767dab

On Friday, March 6th 2020, the City of Hot Springs Davidson Wastewater Treatment Plant (permit number AR0033880)experienced a poor quality effluent. As a result, the Blending Valve was opened at 2:00pm to blend water from the Equalization Pond to aid water quality going into Lake Catherine. At 1037 on March 7, 2020; the blending valve was closed and the Equalization Pond is isolated. Approximately 3.5 Million Gallons went through the Blending Valve and into UV Disinfection.

If you have any questions or concerns, please feel free to call or email anytime.

Thank you,

*Harold Mauldin*
*Facilities Operations Manager*
*City of Hot Springs*
*501-262-1125*