



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: This is an ongoing overflow that began on 1/8/24

Location of event: Gulpha (Manhole 1750)

Sample collection date and time: 2/8/24 @ 1251

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 93.3 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This is an ongoing overflow. This is the third test for this event. We will check the site again out of an abundance of caution.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs