



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant
320 Davidson Drive Hot Springs, Arkansas 71901
Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/23/24

Location of event: Hot Springs Creek (Manhole 1865& 1866)

Date and time of notification: 1/23/224 @ 1426

Sample collection date and time: 1/23/24 @ 1448

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli - >2419.6 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, and site 4 until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs